

Fakulti:	<b>FAKULTI KEJURUTERAAN ELEKTRIK</b>		
Nama Matapelajaran : MAKMAL TAHUN TIGA UMUM	Semakan	: 3	
Kod Matapelajaran : SKEE 3732	Tarikh Keluaran	: Sept 2016	
	Pindaan Terakhir	: Sept 2017	
	No. Prosedur	: PK-UTM-FKE-(O)-08	



**FAKULTI KEJURUTERAAN ELEKTRIK  
UNIVERSITI TEKNOLOGI MALAYSIA  
KAMPUS SKUDAI  
JOHOR**

**SKEE 3732  
BASIC CONTROL LABORATORY  
(Experiment 2)  
ANGULAR POSITION CONTROL**

<p>Disediakan oleh:</p> <ol style="list-style-type: none"> <li>1. Dr Shahdan Sudin</li> <li>2. Dr Sophan Wahyudi Nawawi</li> <li>3. Prof Madya Zamani Md Zain</li> <li>4. Prof Dr Yahaya Md Sam</li> <li>5. Prof Madya Dr Zaharudin Mohamed</li> </ol>	<p>Tandatangan P.A.M: Cop:</p> <p>Tarikh:</p> <p>Disahkan oleh:</p> <p>Tandatangan K.J.: Cop:</p> <p>Tarikh:</p>
--	--

**Recommended References:**

1. Norman S. Nise, Control Systems Engineering (6th Edition), John Wiley and Sons, 2008
2. Katsuhiko Ogata, Modern Control Engineering (4th Edition). Pearson Education International, Inc., 2002.

## **ANGULAR POSITION CONTROL**

---

### **Equipment Required**

**ED-4400B** DC Servo Trainer

Oscilloscope

### **Objectives**

1. To investigate the angular position control performance and response of the servo motor under proportional control.
2. To investigate the position controller step response for various levels of proportional gain
3. To investigate the use of velocity feedback as a means of improving the transient response of an angular position control system.

### **Introduction**

This experiment give an introduction to control engineering principals by firstly considering the operating characteristics of the individual elements used in typical control engineering systems. In simple position control system, an error signal proportional to the difference between input of set position and actual position is generated. The error signals are then fed into the controller. The output from the controller drives the motor closer to the desired position. The analysis on the actually respond of the system to various steady state and transient operating criteria is observed. Some examples where accurate position control is required is the position control of the gun turret on a battle tank, which must be capable of rapid aiming, target tracking and rejection of external disturbances.

The full servomotor block connection for this experiment is shown in Figure 1.1. It is important that this block connection is maintained throughout this experiment.




Figure 1.1 Servomotor block

References:


1. Norman S. Nise, Control Systems Engineering (6th Edition), John Wiley and Sons, 2008
2. Katsuhiko Ogata, Modern Control Engineering (4th Edition). Pearson Education International, Inc., 2002.

## Procedure

In this laboratory, there are four experiments need to be performed.

### A. Basic Tests and Dead Zones

1. Connect the equipment to give the equivalent block diagram as shown in Figure A.1. Use the P only in the PID module as the proportional controller,  $K_p$
2. Switch on the power and set the initial setting for the reference position to 180 degree with  $K_p = 0.2$
3. Slowly turn the reference position dial clockwise and verify that the angular position output gives the same clockwise direction.
4. Repeat step 3 in the anti-clockwise direction.
5. If the output shaft gives the opposite direction to the reference position, interchange the polarity connection at the motor driver output in Figure 1.1.
6. Slowly turn the reference position dial clockwise until the output shaft just begins to move. Read the angle ( $\theta_1$ ) on the reference position dial.
7. Turn the reference position dial anti-clockwise, and note the angle ( $\theta_2$ ) at which the output dial just begins to move.
8. The difference between these angles ( $\theta_1 - \theta_2$ ) is the effective dead-zone width of the controller.
9. Record the difference in Table A.1.
10. Repeat the above procedure for  $K_p = 0.4, 0.6, 0.8, 1.0$ .



**Figure A.1:** Closed loop DC motor position control

**ATTENTION: PLEASE SEPARATE THE POWER SUPPLY CONNECTIONS FOR THE MOTOR DRIVER FROM THE OTHER POWER SUPPLY CONNECTIONS.**

**ASK THE LAB SUPERVISOR/TECHNICIAN TO VERIFY YOUR CIRCUIT CONNECTION BEFORE YOU PROCEED**

**Table A.1:** Effective Dead-zone for Proportional Controller

<b>Proportional Gain (<math>K_p</math>)</b>	<b>Width of input reference (<math>\theta_1 - \theta_2</math>)</b>
<b>0.2</b>	
<b>0.4</b>	
<b>0.6</b>	
<b>0.8</b>	
<b>1.0</b>	

**B. Angular Position Transducer Calibration**

1. Use the same connection as in part A.
2. Switch on the power and set the initial setting for the output potentiometer position to 180 degree. Record the corresponding voltage.
3. Slowly turn the servomotor output shaft until the output potentiometer gives a specified angle.
4. Choose 5 positive and 5 negative angles for the output potentiometer, and record the corresponding position sensor output in Table B.1.

**Table B.1:** Output shaft angular position sensor calibration

	<b>Indicated angle of Output shaft (degree)</b>	<b>Position sensor output (V)</b>
Decreasing negative angle value		
	0	
Increasing positive angle value		

### C. Servo Trainer position control: Step Response


1. Use the same connection as in Part A. In this part, a square wave input will be applied to the system as reference position and the output response will be measured using an oscilloscope.
2. Connect the square wave signal provided to the system at 0.1Hz.
3. Sketch the angular position output signal from oscilloscope for  $K_p = 0.1$ .
4. Measure the percent overshoot ( $\%OS$ ), peak time ( $T_p$ ) and settling time ( $T_s$ ) from the output responses.
5. Repeat for  $K_p = 0.2, 0.4, 0.6, 0.8$  and 1.0
6. Record the  $\%OS$ ,  $T_p$ , and  $T_s$  for different values of  $K_p$  in Table C.1.

Table C.1: Step response over various gain  $K_p$

<b>Propotional Gain <math>K_p</math></b>	<b>%OS</b>	<b><math>T_p</math> (s)</b>	<b><math>T_s</math> (s)</b>
0.1			
0.2			
0.4			
0.6			
0.8			
1.0			

### D. Angular Position Control: Velocity Feedback

1. Connect the equipment corresponds to the block diagram shown in Figure D.1. The difference is just an additional minor feedback loop as compared to the connection in Part C.



**Figure D.1:** Closed loop DC motor Position control with velocity feedback

2. Set the Proportional controller,  $K_p = 0.2$  and the velocity feedback gain,  $K_v = 1$ .
3. Sketch the angular position output signal read from oscilloscope.
4. Measure %OS,  $T_p$ , and  $T_s$ , from the output response.
5. Repeat for  $K_p = 0.2, 0.4, 0.6, 0.8$  and  $1.0$
6. Record the %OS,  $T_p$ , and  $T_s$  for different values of  $K_p$  in Table D.1.

Table D.1: Step response (using velocity feedback) over various gain  $K_p$

Propotional Gain $K_p$	%OS	$T_p$ (s)	$T_s$ (s)
0.2			
0.4			
0.6			
0.8			
1.0			

## Discussion and general conclusion

- 1) From Experiment B:
  - a. Plot the graph using the data from Table B.1.
  - b. Calculate the angle sensor constant,  $K_\theta = \frac{\Delta\theta}{\Delta V}$
  - c. Describe the relationship between the indicated angle and the position sensor output voltage.
- 2) From Experiment C:
  - a. Discuss the relative performance of the controller with various gains  $K_p$ .
  - b. Sketch the output waveform from the oscilloscope.
- 3) From Experiment D:
  - a. Explain why the velocity feedback has a beneficial effect on the system transient response.
  - b. Sketch the output waveform from the oscilloscope.

### For long report.

1. In your own words, explain the relationship between the voltage and the position angle of the DC motor.
2. Draw in details, the output response of the system for different gains.
3. Carry out the time domain analysis on the system output response.
4. Discuss the effect of velocity feedback on the system transient response.
5. By using Matlab, compare your simulation results with experimental results.